

Emission Test Certificate

Monday, November 23rd, 2015

Supplier: USG Boral Australia (251 Salmon Street, Port Melbourne, VIC 3207)

Sample Description: Sheetrock Brand Wall Board

Date Tested: July 2014 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

ASTM D5116	Sheetrock Brand Wall Board
Total Volatile Organic Compound Emission Rate	<0.006mg/m ² /hr
Formaldehyde Emission Rate	<0.011mg/m ² /hr
<p><i>The above results may be considered representative of the product specifications that are made from the same raw material by USG Boral Australia which includes Sheetrock Brand Ceiling Board and Sheetrock Cove.</i></p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV140736a