

# VOC Content Test Certificate

Tuesday July 29<sup>th</sup>, 2008

Manufacturer: Boral Plasterboard (676 Lorimer Street, Port Melbourne Victoria 3207)

Sample Description: Casting Plaster

Date Tested: July 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia</b>  <b>Green Star Office Design V2 IEQ-13</b>  <b>Green Star Office Design V3 IEQ-13</b>  <b>Green Star Office Interiors V1.1 IEQ-11</b>	<b>Casting Plaster</b>
Dry Wall and Panel Adhesive 50 grams per Litre maximum	<b>&lt;10 grams per Litre</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

CV080716