

VOC Content Test Certificate

Tuesday July 29th, 2008

Manufacturer: Boral Plasterboard (676 Lorimer Street, Port Melbourne Victoria 3207)

Sample Description: Hard Finish (also known as Hard Finish SA, Hard Finish NSW

Hard Finish Vic/Qld)

Date Tested: July 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Design V3 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Hard Finish Hard Finish SA Hard Finish NSW Hard Finish VIC/QLD
Dry Wall and Panel Adhesive 50 grams per Litre maximum	<10 grams per Litre



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant

CV080716