

VOC Content Test Certificate

Monday August 17th, 2009

Supplier: Plasterboard (676 Lorimer Street, Port Melbourne Victoria 3207)

Sample Description: Lite Finish finishing compound

Date Tested: August 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Lite Finish
Dry Wall and Panel Adhesive 50 grams per Litre maximum	<10 grams per Litre
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Lite Finish
Dry Wall and Panel Adhesive 50 grams per Litre maximum	<10 grams per Litre



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0908-04